

To: jschulte@orsanco.org[jschulte@orsanco.org]
Cc: Billie J. Suder[Ex. 6 - Personal Privacy] Bruce
Whitteberry[bruce.whitteberry@gcww.cincinnati-oh.gov]; Maysville
[Ex. 6 - Personal Privacy]; Ward, Harold
D[Harold.D.Ward@wv.gov]; Ryan Watts[irononwater@Ex. 6 - Personal Privacy] Jeff
Vogt[Jeff.Vogt@gcww.cincinnati-oh.gov]; Roney, Julie (EEC)[Julie.Roney@ky.gov]; Portsmouth
Water[lab@post.ci.portsmouth.oh.us]; Maysville Water - Greg England[maysvillewtp@gmail.com]; Mike
Eggert[Michael.Eggert@epa.state.oh.us]; Dorsey, Mike H[Mike.H.Dorsey@wv.gov]; Ashland
Water[monk8874@yahoo.com]; Nicole Estes[nestes@lwcky.com]; Richard.Stuck@gcww.cincinnati-
oh.gov[Richard.Stuck@gcww.cincinnati-oh.gov]; robert.francis@ky.gov[robert.francis@ky.gov]; Russell
Water - [Ex. 6 - Personal Privacy]@gmail.com; [Ex. 6 - Personal Privacy]@wvawater.com];
Smith, Art[Smith.Art@epa.gov];
sutherland@post.ci.portsmouth.oh.us[sutherland@post.ci.portsmouth.oh.us]; [Ex. 6 - Personal Privacy]
[Ex. 6 - Personal Privacy] 6 - Personal Privacy
From: Sandra.Johnson@amwater.com
Sent: Fri 2/14/2014 11:22:05 PM
Subject: RE: Fields Creek Coal Slurry Spill
Scan.pdf

On Wednesday evening, the Huntington team went to the Winfield Locks and Dam. We collected samples every hour at this location from 4pm until 10pm . Slight organic odor was noticed and conductivity show some rise during the sampling time.
Samples were collected and brought back to lab to run GC/MS analysis.

Every sample appeared clear except for one small peak that when compared to earlier samples (in January) was not there. Blanks before and after these samples were negative for this peak.

Unsure if it is anything to be concerned about but I am not able to find any data on it in searches of internet and other databases. I wanted to share in hopes that someone could confirm.
Library search is attached.

(See attached file: Scan.pdf)

We have began feeding PAC in response to arrival time based on your time calculations and increasing sample collection of raw water.

Ex. 6 - Personal Privacy

Supervisor, Water Quality and Environmental Compliance
Western Division
West Virginia American Water
4002 Ohio River Road
Huntington, WV 25702

Ex. 6 - Personal Privacy

Fax: 304.525.3495
sjohnson@wvawater.com

"Life can only be understood backward, but it can only be lived forward"
-Soren Kierkegaard